

Annexure C


PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. PHED/WNS/36/2024-25

Dated: 18/07/2024

It is certified that an inspection team headed by Sri K Ramesh, Assistant Executive Engineer, from Bangalore Urban District, PHED inspected the **Royale Concorde International School, No.31**, 1st Main Road, Chamarajpet, Bangalore-560018 on 16/07/2024 (date of inspection) and on the basis of Water Test Report (Attached) bearing No. SLNTL2400700320 dated: 16/07/2024 of SLN Testing Lab (PHED Approved Lab) certified that the Royale Concorde International School, No.31, 1st Main Road, Chamarajpet, Bangalore-560018 has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 17/07/2027.

Signature with Seal: 
Assistant Executive Engineer
Department of Public Health Engineering
Name: K Ramesh
(P.H.E.D.)
Bangalore

Designation: Asst. Executive Engineer

Name & Address of the Office/
Department: P.H.E.D., P.W.D.
Building, K.R.Circle,
Bangalore-560001.

To:

Royale Concorde International School,
No.31, 1st Main Road, Chamarajpet,
Bangalore-560018.

For Royale Concorde International School

Principal

For Royale Concorde Educational Trust

Chairman



SLN TESTING LABORATORY

An ISO 9001:2015, ISO14001:2015, ISO 45001:2018

& GLP Certified Laboratory

#23, JDN Layout 10th Cross, Raghavendra Industrial Area, Thigalarapalya Main Road,

Peenya 2nd Stage, Bengaluru - 560058, Karnataka.

Mob : 9538888098, 9538888097 E - mail: info@slnlabs.com, Web : www.slnlabs.com



TEST REPORT

Page No. 1 of 1

Report No : SLNTL2400700320	Report Date : 16/07/2024
Issued To: M/S. Royale Concorde International School # 31, 1st Main Near Prakash Cafe Chamrajpet Bangalore-560018	Customer Reference : Verbal
	Date of Receipt : 13/07/2024
	Date of test start : 13/07/2024
	Date of Completion of test : 16/07/2024
Sample Received By : Customer	Sample Particulars : Borewell Water

Parameters	Results	Maximum Acceptable Limits (in mg/L)	Maximum Permissible Limits (in mg/L)	Test Method
		(As per IS 10500:2012)		
Colour, Hazen Units	<5	5	15	IS:3025/Part-4
Odour	Agreeable	Agreeable	Agreeable	IS:3025/Part-5
Turbidity, NTU	1.0	1	5	IS:3025/Part-10
pH Value	7.48	6.5 – 8.5	No Relaxation	IS:3025/Part-11
Total Hardness as CaCO ₃ , mg/L	280.0	200	600	IS:3025/Part-21
Calcium as Ca, mg/L	60.0	75	200	IS:3025/Part-40
Magnesium as Mg, mg/L	31.5	30	100	IS:3025/Part-46
Chloride as Cl, mg/L	110.0	250	1000	IS:3025/Part-32
Total Dissolved Solids, mg/L	623.0	500	2000	IS:3025/Part-16
Sulphate as SO ₄ , mg/L	24.7	200	400	IS:3025/Part-24
Nitrate as NO ₃ , mg/L	2.6	45	No Relaxation	IS:3025/Part-34
Fluoride as F, mg/L	0.3	1.0	1.5	IS:3025/Part-60
Iron as Fe, mg/L	<0.1	0.3	No Relaxation	IS:3025/Part-53
Total Alkalinity as CaCO ₃ , mg/L	244.0	200	600	IS:3025/Part-23
Total Coli form, MPN/100ml	Not Detected	Not Detectable		IS 1622-1981
E. Coli, MPN/100ml	Not Detected	Not Detectable		IS 1622-1981

Remarks: The given water sample meets to maximum permissible limits as per IS 10500:2012 for above physical, chemical and microbiological testing.

*****End of the Report*****



Authorised Signatory

Note : 1. The results listed pertain only to the tested samples and applicable parameters.

2. Samples will be destroyed after 15 days from the date of issue of test certificates unless & otherwise specified and all perishable samples will be destroyed immediately after tests conducted.

3. This report is not be reproduced either wholly or in part and can not be used as an evidence in the court of law and should not be used in any advertising media without prior written permission. For Royale Concorde Educational Trust

4. Sampling not done by us, unless specified.

For Royale Concorde International School